Dow Silicones Belgium SPRL

Parc Industriel Zone C rue Jules Bordet B-7180 Seneffe Belgium

Tel: +32 64 888000 Fax: +32 64 888401 e-mail: construction.marketing@dowcorning.com website: www.dowcorning.com/construction



Agrément Certificate 16/5306 Product Sheet 99

DOWSIL PANEL BONDING SYSTEMS

SUPPLEMENT TO DOWSIL PANELFIX SYSTEM

The BBA has examined independent test data or witnessed tests which confirm that the following BBA-approved façade panels are compatible for use within the scope of Product Sheet 1 of this Certificate:

Certificate title Trespa Wall Cladding Systems — Meteon Panels	Company name	Panel preparation type ⁽¹⁾ Non-porous	BBA Certificate 99/3629	Panel fire grade	
				Standard grade Fire resistant (FR) grade	D-s2, d0 B-s2, d0 B-s1, d0
Marley Eternit Cladding Panels — Natura and Natura Plus Cladding Panels	Marley Eternit Ltd	Porous	06/4355	A2-s1, d0	

⁽¹⁾ See section 12 of Product Sheet 1 of this Certificate.

A detailed description of the panels is given with the relevant BBA Agrément Certificate.

Prior to installation, detailed calculations should be carried out on a site-by-site basis to determine the suitability of the DOWSIL PanelFix System when used in conjunction with the above-mentioned panels.

Attention should be paid to panel preparation to ensure the correct conditions in which the DOWSIL adhesive can be applied. Panel preparation is detailed in section 12 of Product Sheet 1 of this Certificate.

The BBA has awarded this Certificate to the company named above for the system described herein. This system has been assessed by the BBA as being fit for its intended use provided it is installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Date of First issue: 29 March 2016

Simon Wroe Head of Approvals — Engineering Claire Curtis-Thomas Chief Executive

Clain.

Certificate amended on 17 January 2018 to update the company and product name.

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

British Board of Agrément Bucknalls Lane

Watford Herts WD25 9BA tel: 01923 665300 clientservices@bba.star.co.uk www.bbacerts.co.uk